



## SUITABILITY FOR USE

### UNI 11021

### PRODUCTS AND SYSTEMS FOR PAINTING ROOMS WITH

### PRESENCE OF FOOD

### TEST REQUIREMENTS AND METHODS

With reference to Test Report n° 19LA04527 dated 31/01/2020, this certificate of suitability for the product is issued

#### VALPAINT I-BETON

N°	Test	Method	Analytical value	Target value	Result
----	------	--------	------------------	--------------	--------

#### Essential requirements

7.1	Dirt pick-up	UNI 10792	$\Delta L = 2,20$	$\Delta L \leq 3,00$	PASS
7.2	Release of odour	Appendix A	0,8	$\leq 1,0$	PASS

#### Special requirements

8.1	Wet scrub resistance – brush method	UNI 10560	$> 5000$	$\geq 5000$	PASS
8.2	Cleanability test	Appendix B	$\Delta E = 0,5$	$\Delta E \leq 3,00$	PASS
8.3	Moulds resistance	Appendix C	0	$\leq 1,0$	PASS
8.4	Resistance to liquids	UNI EN ISO 2812-1 (method 3)	Washing agent A: very slight opacification Washing agent C: slight opacification	Mild alteration of detergents A, B and C	PASS
8.6	Resistance to temperature shocks	Appendix D	No alteration	No alteration	PASS
8.7	Resistance to humidity	UNI EN ISO 6270-1	No alteration	No alteration	PASS



INNOVHUB  
STAZIONI SPERIMENTALI  
PER L'INDUSTRIA

innovazione e ricerca

SSOG

STAZIONE SPERIMENTALE  
PER LE INDUSTRIE DEGLI OLI  
E DEI GRASSI

SEDE OPERATIVA:

Via Giuseppe Colombo, 79 - 20133 Milano

Tel +39 02 7064971 - Fax +39 02 2363953

sales.innovhub@mi.camcom.it

www.innovhub-ssi.it

## RESULT

### *Painting system suitable for environments where food is present*

- *Suitable for walls, ceilings and surfaces for which resistance to washing and mold is required*
- *It can be washed with*
  - *Washing agent A – chlorine-active*
  - *Washing agent C – acid descaling*
- *Suitable for cold rooms*
- *Suitable for rooms with average humidity greater than 80%*

**Head of sector**

(Mr. Gianmaria Gasperini)

**Laboratory Manager**

(Mr. Gianmaria Gasperini)